



Ref. Certif. No.

US-34329-UL

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**

CB TEST CERTIFICATE

Product

Power Distribution Unit

Name and address of the applicant

UNIPOWER L L C
210 N UNIVERSITY DR, SUITE 700
CORAL SPRINGS FL 33065
UNITED STATES

Name and address of the manufacturer

UNIPOWER L L C
65 INDUSTRIAL PARK RD
DUNLAP, TN 37327
UNITED STATES

Name and address of the factory

Note: When more than one factory, please report on page 2

UNIPOWER L L C
65 INDUSTRIAL PARK RD
DUNLAP, TN 37327
UNITED STATES

[Additional Information on page 2](#)

Ratings and principal characteristics

See Page 2

Trademark (if any)

Unipower



Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DPP1U Series

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 60950-1:2006 / A11:2009 / A1:2010 / A12:2011 / A2:2013; National Differences specified in the CB Test Report.

[Additional Information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 60950-1:2005/AMD1:2009, IEC 60950-1:2005/AMD2:2013, IEC 60950-1:2005

As shown in the Test Report Ref. No. which forms part of this Certificate

E210994-A9-CB-1 issued on 2019-08-30

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-08-30

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-34329-UL

Factories:

DONGGUAN TEAMWISE ELECTRONICS CO LTD
1 AO BEI RD
CROSS XIANG XIN WEST RD
YANTIAN, FENGGANG
DONGGUAN
GUANGDONG 523701 CHINA

Ratings:

Nominal 21-60Vdc
Up to 150A per feed (max. 2 feeds)

Nominal 10.5 - 15 Vdc
Up to 150A per feed (max. 2 feeds)

Output Rated:

Up to 150A per feed (Up to 22.5A per position)

Input/output Short Circuit Rating 10K AIC

Additional information (if necessary)



- UL (US), 333 Pflingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-08-30

Signature:

Jolanta M. Wroblewska