



Ref. Certif. No.

US-34303-UL

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**

CB TEST CERTIFICATE

Product	Power Distribution Unit - Single phase
Name and address of the applicant	UNIPOWER L L C 210 N UNIVERSITY DR, SUITE 700 CORAL SPRINGS FL 33065 UNITED STATES
Name and address of the manufacturer	UNIPOWER L L C 65 INDUSTRIAL PARK RD DUNLAP, TN 37327 UNITED STATES
Name and address of the factory	UNIPOWER L L C 65 INDUSTRIAL PARK RD DUNLAP, TN 37327 UNITED STATES
Note: <i>When more than one factory, please report on page 2</i>	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	Unipower 
Type of Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	DPP2U Series
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 60950-1:2006 / A11:2009 / A1:2010 / A12:2011 / A2:2013; National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60950-1:2005/AMD1:2009, IEC 60950-1:2005/AMD2:2013, IEC 60950-1:2005
As shown in the Test Report Ref. No. which forms part of this Certificate	E210994-A8-CB-1 issued on 2019-08-28

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-08-28

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-34303-UL

Factories:

IONOTE LTD
6 LING DONG RD
LINCUN INDUSTRIAL CENTER
TANGXIA TOWN
DONGGUAN
GUANDONG 523710 CHINA

Ratings:

Nominal 21-60Vdc
450A per feed A / B (max. 2 feeds)
Output Rated:
21-60Vdc, 100A Max per Position; 450A Max per side A / B
Input/output Short Circuit Rating 10K AIC
(See Miscellaneous Enclosure for derating factors based on max. operating ambient.)

Additional information (if necessary)



- UL (US), 333 Pfinqsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-08-28

Signature:

Jolanta M. Wroblewska